



Mini AC current clamps 20/200 A A 1783

Instruction manual

Version 1.1.1; Code No. 20 753 286

Distributor:

Manufacturer:

Metrel d.o.o.
Ljubljanska cesta 77
SI-1354 Horjul
Slovenia
[e-mail: info@metrel.si](mailto:info@metrel.si)
<https://www.metrel.si>



Mark on your equipment certifies that it meets requirements of all subjected EU regulations



Hereby, Metrel d.o.o. declares that the A 1783 is in compliance with subjected EU directives. The full text of the EU declaration of conformity is available at the following internet address <https://www.metrel.si/DoC>.



Mark on your equipment certifies that it meets requirements of all subjected UK regulations.



Hereby, Metrel d.o.o. declares that the A 1783 is in compliance with subjected UK regulations. The full text of the UK declaration of conformity is available at the following internet address <https://www.metrel.si/UK-DoC>.

© 2023 METREL

The trade names Metrel®, Smartec®, Eurotest®, Auto Sequence® are trademarks registered in Europe and other countries.

No part of this publication may be reproduced or utilized in any form or by any means without permission in writing from METREL.

Table of contents

1	General Description	4
1.1	Typical applications	4
2	Safety and operational considerations	5
2.1	Warnings and notes	5
2.2	Standards applied.....	6
3	Current clamp operation.....	7
4	Inspection	8
5	Cleaning.....	8
6	Service and Calibration	8
7	Technical specifications.....	9

1 General Description

The **A 1783** current clamps are designed for measuring alternating currents on insulated conductors on low power installations: 50 mA ÷ 200 A. They are designed for Metrel Power Quality Instruments MI 2893 / MI 2892 / MI 2885 / MI 2884 / MI 2883.

The current transducer is housed in a plastic case that maintains double insulation. Parts are shown on figure below:




Figure 1: A 1783 current clamps

1.1 Typical applications

Power Quality Measurement

The A 1783 current clamps have linear response through wide frequency bandwidth. Therefore, they are well suited for:

- Power Quality auditing,
- EN 50160 or troubleshooting. Particularly for:
 - o Current distortion measurement
 - o Inrush measurement
 - o Harmonics measurement for frequency
 - o Functional testing of appliances, machines, etc.

High precision and measurement range up to 30 A / 260 A can cover most current measurements on the secondary side of current transformer (CT) without opening of current circuit.

Energy and Power Measurement



The A 1783 current clamps have small phase shift over wide frequency range. Therefore, they are well suited for:

- Power and energy measurements (active, reactive, apparent)
- Power factor measurements
- Power/Energy efficiency






2 Safety and operational considerations

2.1 Warnings and notes

In order to maintain the highest level of operator safety while carrying out various tests and measurements Metrel recommends keeping your A 1783 Mini AC current clamp in good condition and undamaged. When using the A 1783, consider the following general warnings:

- ❑ The  symbol on the A 1783 means »Read the Instruction manual with special care for safe operation«. The symbol requires an action!
- ❑ If the test equipment is used in a manner that is not specified in this Instruction manual, the protection provided by the equipment might be impaired!
- ❑ Adhere to local and national safety codes. Individual protective equipment must be used to prevent shock and arc blast injury where hazardous live conductors are exposed.
- ❑ Before each use, inspect the A 1783 Current Clamp and its latching system for any damage. Pay particular attention to the insulation surrounding the jaw. Look for cracks or missing portions of the clamp housing or output cable insulation. Also look for loose or weakened components. Don't use current sensor if the wear indicator of the cable connection is visible.
- ❑ Do not use a clamp that is cracked, damaged, or has a defective cable.
- ❑ Do not use the A 1783 Current Clamp to measure bare conductors carrying a voltage higher than 30 V ac rms or 42 V ac peak.
- ❑ Never use the clamp on a circuit with voltages higher than 300 V CAT II (insulated conductors).
- ❑ De-energize the installation on which current will be measured or adopt safe operating procedures during application and removal of the current clamp.
- ❑ Use extreme caution when working around bare conductors or bus bars (follow the requirements of EN 50191).
- ❑  Do not apply around or remove from UNINSULATED HAZARDOUS LIVE conductors, which may render electric shock, electric burn, or arc flash.

Markings on the A 1783:

Symbol	Description
	Read the Instruction manual with special care to safety operation«. The symbol requires an action!
	Do not apply around or remove from HAZARDOUS LIVE conductors.
	Mark on your equipment certifies that it meets requirements of all subjected EU regulations.
	Mark on your equipment certifies that it meets requirements of all subjected UK regulations.
	This equipment should be recycled as electronic waste.

2.2 Standards applied

The A 1783 Current Clamp is manufactured and tested in accordance with the following regulations:

Electromagnetic compatibility (EMC)

EN 61326 - 1	Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements
EN 61326 - 2 - 2	Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-2: Particular requirements - Test configurations, operational conditions and performance criteria for portable test, measuring and monitoring equipment used in low-voltage distribution systems

Safety (LVD)

EN 61010 - 1	Safety requirements for electrical equipment for measurement, control and laboratory use – Part 1: General requirements
EN 61010 - 2 - 032	Safety requirements for electrical equipment for measurement, control and laboratory use – Part 2-032: Particular requirements for hand-held and hand-manipulated current sensors for electrical test and measurement

Note about EN and IEC standards:

- Text of this manual contains references to European standards. All standards of EN 6XXXX (e.g. EN 61010) series are equivalent to IEC standards with the same number (e.g. IEC 61010) and differ only in amended parts required by European harmonization procedure.

3 Current clamp operation

Step 1

Connect A 1783 Current Clamps to the desired input on the measuring instrument.

Step 2

Clamp the probe around the insulated current-carrying conductor(s) to be measured. Make sure that probe jaws are tightly closed around the conductor(s). In the case of measuring current near live, naked conductor(s), remove electrical power from wires, before clamping (follow the requirements of EN 50191).




Figure 2: Current clamps A 1783- connection to the measuring instrument




Figure 3: Current clamps proper position

Position the clamp with the current direction indicator pointing toward the load side. If install the clamp in the opposite direction, the phase displacement will deviate 180 degrees.

Step 3

Select Phase and Neutral clamps to A 1783 in Connection setup menu on your instrument. Select proper Clamps range on the PQA (same as it was selected on the clamps Step 2).

Select Clamps		SETUP	
A1179	(20A, 200A, 2000A)	I1	2.839A
A1257	(30A, 300A, 3000A)	I2	2.499A
A1287	(30A, 300A, 3000A)	I3	2.203A
P50	(5A, 30A, 300A, 1000A)	In	7.534A
A1391	(40A, 300A)	Clamps selected	A1783
A1636	(2000A)	Status	N/A
A1717	(100A, 1000A)	Clamps range	20.00A
A1783	(20A, 200A)	CURRENT TRANSFORMER	
		Primary current	1A
		Secondary current	1A

Step 4

Observe the current value and waveform on the instrument's display.

4 Inspection

To maintain operator safety and ensure reliability of the A 1783 Current Clamp, it is good practice to inspect it on a regular basis. Check that the enclosure and optional connection are without defects such as scratches or breaks.

Jaw surface must be clean. Pollution on jaw surfaces reduces the current clamp sensitivity.

5 Cleaning

No special maintenance is required for the housing. To clean the surface of the A 1783 use a soft cloth slightly moistened with soapy water or alcohol. Then leave the A 1783 to dry totally before use.



Warnings:

- ❑ **Do not use liquids based on petrol or hydrocarbons!**
- ❑ **Do not spill cleaning liquid over the A 1783!**

6 Service and Calibration

It is essential that your clamp is regularly calibrated in order to guarantee the technical specification listed in this Instruction manual. We recommend 2-year calibration interval. Metrel encloses an original calibration certificate with every new instrument and clamp.

For recalibration and repairs under or out of warranty time please contact your distributor for further information.



Warning:

- ❑ **Only a competent, authorized person is allowed to carry out service intervention!**

7 Technical specifications

Nominal current (I_{Nom})	20 A / 200 A
Nominal current range	5 % I_{Nom} ... 100 % I_{Nom}
Maximal current (I_{Max})	30 A / 260 A
Output signal	10mV/A (20 A range) 1mV/A (200 A range)
Bandwidth	45 Hz ... 60 Hz
Uncertainty	\pm (0,5 % of reading + 0,02 % FS)
Phase Error	$\pm \leq 0,5^\circ$ (45 – 5 kHz)
External fields	30 A/m (No influence)
Continuity of measurements	20 A (continuous) 30 A (40 min / 20 min intermitted)

Dimensions & Mechanical data:

Current sensor type.....	D
Length of connection cable	1.5 m
Jaw opening.....	24 mm
Maximum conductor sizes.....	fi < 24 mm
Dimensions (W x H x L)	64 mm x 130 mm x 26 mm
Weight	300 g

Safety specification:

Over-voltage category	600 V CAT III
Pollution degree	2
Degree of protection	IP 40

EMC:

Emission.....	Class B
Immunity	Portable equipment

Environment conditions:

Working temperature range	-15 °C ... 50 °C
Storage temperature range.....	-20 °C ... 60 °C
Humidity range	0 %RH ... 80 %RH
Reference temperature range.....	25 °C \pm 5 °C @ 40 %RH ... 60 %RH
Altitude.....	up to 2000 m
Operation	Indoor use

Substitute Electric Model for A 1783 Mini AC current clamps 20/200 A

Equivalent circuit diagram for current clamp measurement:




Figure 4: A 1783 Mini AC current clamps 20/200 A - block diagram

Symbols on circuit diagrams have following meaning:

I_m	Measured (AC) current, primary current
I_s	Secondary transformer current